

Spill Summary Report for NRC Report #1272049

Report Date: 9/14/2022

Report Time: 4:08 PM EDT

Region II Hotline Log Entry Information

Data ID: 2626834

Date Of Report: 2/25/2020

NRC #: 1272049

State #:

ERNS #:

Material Type: Oil

Receiver: Budroe

Material / Amount:

OIL, MISC: TRANSFORMER, NON-PCB (75 GALLON(S));

Location:

Street: FISHER AVE AND HILLSIDE AVE

City: EAST CHESTER

County: WESTCHESTER

State: NY

Latitude: 40.956102000000016

Longitude: -73.814742

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

STORM SEWER

State Or EPA Responded:

RP/PRP Response

Initial EPA Action:

Contact RP

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 1253828

Date: 2/25/2020	Time: 13:58:23	
Duty Officer/Responder Name: Thomas Budroe	NRC Report #: 1272049	Hotline Log DataID: 2626834
Action Information		
Description: Mr. Cancel informed OSC that the electricity is being made safe and the electrical lines are being shut down. A barrier has been constructed in the storm drain to prevent further migration of the oil. They are currently obtaining the schematics to determine the migration pathway. Con-Ed is conducting the cleanup of the source. A cleanup contractor shall be hired if the spill reaches a waterway.		
Follup-Up:		
Person Contacted		
Name: Felix Cance Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK Phone #: (212)5808383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1272049

INCIDENT DESCRIPTION

*Report taken by NRC at 13:34 on 25-FEB-20

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area: STORM SEWER

Incident occurred on 25-FEB-20 at 13:15 local incident time.

Affected Medium: WATER / STORM SEWER

REPORTING PARTY

Name: FELIX CANCEL

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 3101 20TH AVENUE

ASTORIA, NY 11105

Email Address: cancelxf@coned.com

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: FELIX CANCEL

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

FISHER AVE AND HILLSIDE AVE County: WESTCHESTER

RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As: OIL, MISC: TRANSFORMER, NON-PCB

Qty Released: 75 GALLON(S)

Qty in Water: 75 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER IS REPORTING THAT A TRANSFORMER CAUGHT ON FIRE AND SPILLED AN ESTIMATED 75 GALLONS OF NON-PCB OIL TO THE GROUND AND A STORM SEWER DRAIN. IT IS UNKNOWN IF THE OIL HAS REACHED THE BRONX RIVER.

INCIDENT DETAILS

Package: N/A

Building ID:

Type of Fixed Object: TRANSFORMER

Power Generating Facility: NO

Generating Capacity:

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: STORM SEWER

Tributary of: BRONX RIVER

Nearest River Mile Marker:

Water Supply Contaminated: UNKNOWN

IMPACT

Fire Involved: YES Fire Extinguished: YES

INJURIES: NO Sent to Hospital:

Empl/Crew:

Passenger:

FATALITIES: NO Empl/Crew:

Passenger:

Occupant:

EVACUATIONS: NO Who Evacuated:

Radius/Area:

Damages: NO

<u>Closure Type</u>	<u>Description of Closure</u>	<u>Hours Closed</u>	<u>Direction of Closure</u>
---------------------	-------------------------------	---------------------	-----------------------------

Air: NO

Road: NO

Major

Artery: NO

Waterway: NO

Track: NO

Passengers Transferred: NO

Environmental Impact: NO

Media Interest: NONE

REMEDIAL ACTIONS

CLEAN UP CREW ON-SITE, CLEAN UP UNDERWAY.

Release Secured: YES

Release Rate:

Estimated Release Duration:

WEATHERWeather: RAINY, 16 $\frac{1}{2}$ F

ADDITIONAL AGENCIES NOTIFIED

Federal:

State/Local:

State/Local On Scene: FD

State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)

25-FEB-20 13:41 (770)4887100

USCG DESK AT DHS NOC (USCG LNO)

25-FEB-20 13:41 (202)2828114

DEPT OF HEALTH AND HUMAN SERVICES (SECRETARY'S OPERATION CENTER (SOC))

25-FEB-20 13:41

DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPARTMENT)

25-FEB-20 13:41 (703)7673477

DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)

25-FEB-20 13:41 (202)4655909

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

25-FEB-20 13:41 (202)3661863

U.S. EPA II (MAIN OFFICE)

25-FEB-20 13:44 (732)3214370

BUDROE

USCG NATIONAL COMMAND CENTER (MAIN OFFICE)
25-FEB-20 13:41 (202)3722100
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
25-FEB-20 13:41 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)
25-FEB-20 13:41 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
25-FEB-20 13:41 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
25-FEB-20 13:41 (206)5264911
NEW YORK CITY DEP (BUREAU OF WATER SUPPLY)
25-FEB-20 13:41 (845)3347188
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
25-FEB-20 13:41 (518)4577362
PIPELINE & HAZMAT SAFETY ADMIN (HAZARDOUS MATERIAL ACCIDENT INVESTIGATION)
25-FEB-20 13:41 (202)3664031
REPORTING PARTY (RP SUBMITTER)
25-FEB-20 13:41
SECTOR NEW YORK (COMMAND CENTER)
25-FEB-20 13:43 (718)3544356 CAMPBELL
CTDEP OIL & CHEM SPILL RESP DIV (MAIN OFFICE)
25-FEB-20 13:41 (860)4243338
USCG DISTRICT 1 (COMMAND CENTER)
25-FEB-20 13:41 (617)2238555

ADDITIONAL INFORMATION

*** END INCIDENT REPORT # 1272049 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://nrc.uscg.mil>